



"RE-BUILDING THE CITY'S WATER SYSTEMS FOR THE 21ST CENTURY"

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

February 1, 2023

Addendum No. 2

Your reference is directed to **Contract 1447 – CARROLLTON WATER PLANT BOILER HOUSE FAN MODIFICATIONS** for the Sewerage and Water Board of New Orleans which is due at **11:00 a.m.** Local time on **February 8, 2023.**

This Addendum consists of 1 Page(s) and 1 Attachment(s).

This addendum provides for the following:

- A2.1. This Addendum includes the following attachments (not included in the page count):
- a. Attachment 1 – C1447 Questions and Responses During Bidding – Version 0, Dated February 1, 2023 [Questions 1-3].

The changes, additions, and/or deletions included herein are hereby made part of the Contract Documents for the CP-1447 Carrollton Water Plant Boiler House Fan Modifications project, as fully and completely as if the same were set forth therein. The bidder shall acknowledge receipt thereof on the Form of Proposal.

***** END OF ADDENDUM *****

C1447 – Utility Rack

Questions and Responses During Bidding

Version 0, Dated: February 1, 2023 [Questions 1-3]

BIDDER QUESTION 1: Balance of the units was mentioned. Will a baseline be taken before work begins? There may be imbalance in the fans that could cause vibration.

RESPONSE 1: Contractor to perform a pre-removal balance analysis to establish a baseline.

BIDDER QUESTION 2: Can all motors be done at once? What sequence does the work need to be completed in? Doing multiple at once will cut down on crane mobilizations.

RESPONSE 2: The basis of bids should consider sequential completion of work starting with FD Fan Motor #4, then FD Fan Motor #3, then ID Fan Motor #3.

BIDDER QUESTION 3: Do we have weights on motors?

RESPONSE 3: The equipment tag on FD Fan Motor #4 indicates a motor weight of 5,400 lbs.